

31 August 1970

25X1A9A

Mr. [redacted]
Office of Logistics
Real Estate & Construction Division
Room 905-Ames Building

Bob:

1. Thank you for the specification for Shelving at the Army Map Service. They are very enlightening and should prove very helpful to [redacted]

2. Mr. [redacted] reviewed them carefully and found some strange and important omissions which we should guard against in our specifications. Please note his comments attached, especially his mention of:

Para. 2.6 - Does not specify height.

Para. 2.10 - Calls for sponge edges which could restrict air circulation -- but I leave that up to the Engineers.

Para. 2.12 - The safety features are not automatic. We can not over emphasize Safety. If anyone is ever trapped and injured in these shelves we will all be held responsible.

Para. 3.7 - Acceptance and de-bugging tests could be going on after several months as was proven by problems at RID and NPIC. It would be better that they tie up the vendor, not our operations.

25X1A6A

RECD [redacted] Your [redacted] Engineers may have other comments on these specs.

25X1A9A

C

2 DC

1 EX

SA

C/REB

RO

3 C/REB

4 PE

C/REB

PE

FILE

1255

SSS - Rm. 705 Magazine

25X1